

**Mandatory Language for Monitoring/Reporting Violation
Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The PINE RIDGE WSC SOUTH water system PWS ID 2120019 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This/These violation(s) occurred in the monitoring period(s) 1/1/25 - 3/31/25
<monitoring period of violation>

We are taking the following actions to address this issue:

First quarter report sent to TCEQ 30 days late. We will set a reminder to mail the report for each quarter going forward. (April 10th, July 10th, October 10th and January 10th)
<corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Darlene Tunnell at
903-903-5101 903-569-7572 <water system official's name>
<area code + phone number>

Posted /Delivered on: _____
<Date Posted>

**Monitoring/Reporting Violation Report:
PINE RIDGE WSC SOUTH PWS ID: TX2120019**

DS01		DISTRIBUTION SYSTEM	
First Quarter 01/01/2025 - 03/31/2025			
<u>Analyte Code</u>	<u>Violation ID</u>	<u>Analyte</u>	<u>Rule Citation</u>
0999	90060400	CHLORINE	30 TAC § 290.110(e)(4)(A), § 290.110(f)(2), § 290.110(f)(3) - Failure to Submit Disinfectant Level Quarterly Operating Report